



ASANSOL MINES BOARD OF HEALTH

Tel. No. (0341) 225-2227
Fax No. (0341) 225-2227

Date: _____
website: <https://asansolminesboardofhealth.org>
e-mail : ambhasansol@gmail.com

BACTERIOLOGICAL EXAMINATION REPORT

Of Water Sample

Report No. 191/B/2021

Date : 23/04/2021

Sample received from :- Sandip Srkar, NANDALAL JALAN SHIKSHA SADAN,
Saraswati Roy Place, Raniganj – 713323, Dist- Paschim Bardhaman,
Ph.No. 9647937367 / 7076427400.

On Collected on 23/04/2021

From :- Drinking Water.

1.	Colony count in agar at 37° c after 48 HRS. per ML of original Water - <u>16</u>
2.	Probable Number of Coliaerogeneso rganism per 100 ML of Original Water - <u>Nil</u>
3.	Faecal Bacilli - <u>Absent</u>
4.	Date of sending Report <u>17-05-2021</u>

Remarks :- 'Satisfactory'

Memo No. 434/21

Date. 20/05/21

Sd/-
Dr. A. K. Sen
MBBS, MD(Micro-Biology)
Signature of Bacteriologist

Copy to :- Sandip Srkar, NANDALAL JALAN SHIKSHA SADAN,
Saraswati Roy Place, Raniganj – 713323, Dist- Paschim Bardhaman,
Ph.No. 9647937367 / 7076427400– for information please.

Health Officer
Asansol Mines Board of Health
Health Officer
Asansol Mines Board of Health

19/5/21